

报告日期: 14/04/2016

SGS Oil, Gas and Chemicals
通标标准技术服务(上海)有限公司
上海测试中心
普工路88号
化学工业区
中国上海

浙江衢化氟化学有限公司
浙江省衢州市巨化中央大道243号
中国

分析报告: ST16-02346.001

警告: 该测试样品由客户或代表客户的第三方提供, 测试报告内容仅与样品相关, 不承担样品所代表的货物。本公司对样品所注明的产地和来源不承担任何责任。

工作订单号:	OPCSH1600924-01CG	BOSS单号:	--
客户编号:		样品描述:	制冷剂 - R410A
采样地点:	无		
样品来源:	客户提供		
样品类型:	无	取样方:	客户
取样日期:	--	收样日期:	14/04/2016
分析日期:	14/04/2016	完成日期:	14/04/2016
容器:	--		

测试项目	方法	结果 单位	最小值	最大值
R-32含量	AHRI 700 Appendix C Part 10	48.72 % (m/m)	48.5	50.5
R-125含量	AHRI 700 Appendix C Part 10	51.28 % (m/m)	49.5	51.5
酸度(以盐酸计)	AHRI 700 Appendix C Part 1	NO DETECT mg/kg	--	1
氯化物	AHRI 700 Appendix C Part 4	通过 ---	--	--
不凝气体(25°C)	AHRI 700 Appendix C Part 5	0.17 % (V/V)	--	1.5
水分	AHRI 700 Appendix C Part 2	8 mg/kg	--	10
高沸物残渣	AHRI 700 Appendix C Part 3	<0.01 % (V/V)	--	0.01
固体颗粒物	AHRI 700 Appendix C Part 3	通过 ---	--	--

** 分析结果结束 **

The results shown in this test report specifically refer to the sample(s) tested as received unless otherwise stated. All tests have been performed using the latest revision of the methods indicated, unless specifically marked otherwise on the report. Precision parameters apply in the determination of the below results. Users of the data shown on this report should refer to the latest published revisions of ASTM D3244; IP 367 and ISO 4259 and when utilising the test data to determine conformance with any specification or process requirement. With respect to the UOP methods listed in the report below the user is referred to the method and the statement within it specifying that the precision statements were determined using UOP Method 999. This Test Report is issued under the Company's General Conditions of Service (copy available upon request or on the company website at www.sgs.com). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues defined therein. This report shall not be reproduced except in full, without the written approval of the laboratory.

报告人

授权签字人

杨卫军
测试工程师

1404201618090000046949

陆益平

通标标准技术服务(上海)有限公司

页码 1 / 1

OGC-ZH_REPORT-2013-05-30-V58

REPORT DATE: 14/04/2016

SGS Oil, Gas and Chemicals
SGS-CSTC Standards Technical Services Shanghai Co., Ltd
OGC Shanghai Testing Centre
No.88 Pugong Road
Shanghai Chemical Industry Park
Shanghai, China

ZHEJIANG QIHUA FLUOR-CHEMISTRY CO., LTD
NO.243 JU HUA CENTRE ROAD,QUZHOU,ZHEJIANG
CHINA

Analysis Report: ST16-02346.001

WARNING: The sample to which the findings recorded herein relate was drawn and / or provided by the Client or by a third party acting at the Client's direction. The Findings constitute no warranty of the sample's representativeness of any goods and strictly relate to the sample. The Company accepts no liability with regard to the origin or source from which the sample is said to be extracted.

JOB ORDER NO. :	OPCSH1600924-01CG	BOSS ORDER NO.:	--
CLIENT ID :		PRODUCT DESCRIPTION :	Refrigerant - R410A
LOCATION :	N/A		
SAMPLE SOURCE :	Supplied by Client		
SAMPLE TYPE :	N/A	SAMPLE BY :	Client
SAMPLED :	--	RECEIVED :	14/04/2016
ANALYSED :	14/04/2016	COMPLETED :	14/04/2016
CONTAINER:	--		

PROPERTY	METHOD	RESULT UNITS	MIN	MAX
R-32 Content	AHRI 700 Appendix C Part 10	48.72 % (m/m)	48.5	50.5
R-125 Content	AHRI 700 Appendix C Part 10	51.28 % (m/m)	49.5	51.5
Acidity (as HCl)	AHRI 700 Appendix C Part 1	NO DETECT mg/kg	--	1
Chloride	AHRI 700 Appendix C Part 4	Pass ---	--	--
Non-Condensable Gas at 25°C	AHRI 700 Appendix C Part 5	0.17 % (V/V)	--	1.5
Water	AHRI 700 Appendix C Part 2	8 mg/kg	--	10
High Boiling Residue	AHRI 700 Appendix C Part 3	<0.01 % (V/V)	--	0.01
Particulates/Solids	AHRI 700 Appendix C Part 3	Pass ---	--	--

**** End of Analytical Results ****

The results shown in this test report specifically refer to the sample(s) tested as received unless otherwise stated. All tests have been performed using the latest revision of the methods indicated, unless specifically marked otherwise on the report. Precision parameters apply in the determination of the below results. Users of the data shown on this report should refer to the latest published revisions of ASTM D3244; IP 367 and ISO 4259 and when utilising the test data to determine conformance with any specification or process requirement. With respect to the UOP methods listed in the report below the user is referred to the method and the statement within it specifying that the precision statements were determined using UOP Method 999. This Test Report is issued under the Company's General Conditions of Service (copy available upon request or on the company website at www.sgs.com). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues defined therein. This report shall not be reproduced except in full, without the written approval of the laboratory.

REPORTED BY

Kevin Yang
Chemist

1404201618080000046948



Page 1 of 1

OGC-En_report-2013-05-30-V58